



Test Report issued under the responsibility of:



TEST REPORT
IEC 60745-1
Safety of Hand-Held Motor-Operated Electric Tools

Report Reference No. : 3146349.51A

Date of issue : 2014-08-21

Total number of pages : 62 pages

CB Testing Laboratory : DEKRA Testing and Certification (Shanghai) Ltd.

Address : 10F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibei Hi-Tech Park, Zhabei District Shanghai 200436 CHINA

Applicant's name : LEE YEONG INDUSTRIAL CO., LTD.

Address : No.2, Kejia Rd., Douliu City, Yunlin County 64057, Taiwan

Test specification:

Standard : IEC 60745-1: 2006 (Fourth Edition)

Test procedure : CB Scheme

Non-standard test method : N/A

Test Report Form No. : IEC60745_1F

Test Report Form(s) Originator : Underwriters Laboratories Inc.

Master TRF : 2010-08

Copyright © 2010 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description : Concrete Saw(Cut-off Machine)

Trade Mark : AGP

Manufacturer : LEE YEONG INDUSTRIAL CO., LTD.


No.2, Kejia Rd., Douliu City, Yunlin County 64057, Taiwan

Model/Type reference : C14; C355; CS355; CS14; SCS14; SCS355; SC14; SC355

Ratings : 220-240 V; 50-60 Hz; 2800 W; n=4500 min⁻¹; ø355 mm


110-120 V; 50-60 Hz; 1700 W; n=4500 min⁻¹; ø355 mm

Class I

Testing procedure and testing location:	
<input checked="" type="checkbox"/> CB Testing Laboratory: Testing location/ address:	DEKRA Testing and Certification (Shanghai) Ltd. 10F #250 Jiangchangsan Road, Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Zhabei District Shanghai 200436 CHINA
<input type="checkbox"/> Associated CB Laboratory: Testing location/ address:	Tested by (name + signature).....: David Yang Approved by (+ signature).....: Chris Feng
<input type="checkbox"/> Testing procedure: TMP Tested by (name + signature).....: Approved by (+ signature).....: Testing location/ address:	
<input type="checkbox"/> Testing procedure: WMT Tested by (name + signature).....: Witnessed by (+ signature).....: Approved by (+ signature).....: Testing location/ address:	
<input type="checkbox"/> Testing procedure: SMT Tested by (name + signature).....: Approved by (+ signature).....: Supervised by (+ signature).....: Testing location/ address :	
<input type="checkbox"/> Testing procedure: RMT Tested by (name + signature).....: Approved by (+ signature).....: Supervised by (+ signature).....: Testing location/ address:	

<p>List of Attachments (including a total number of pages in each attachment):</p> <p>-3146349.51A refers to the requirements of IEC 60745-1:2006 (total 62 pages)</p> <p>-3146349.51B refers to the requirements of IEC 60745-2-22: 2011 +A11:2013 (total 18 pages)</p> <p>-3146349.51C refers to the requirements of EN 60745-1:2009 + A11: 2010 (total 3 pages)</p> <p>-3146349.51D refers to the requirements of EN 60745-2-22: 2011 (total 2 pages)</p>									
<p>Summary of testing:</p>									
<p>Tests performed (name of test and test clause):</p> <p>All appl. clauses of the standard have been done on product at CBTL except clause 14.6, noise and vibration tests.</p> <p>Clause 14.6 was tested in DEKRA Testing and Certification--WenZhou</p> <p>Noise and vibration tests were done at CSIC No.711 Research Institute.</p>	<p>Testing location:</p> <p>DEKRA Testing and Certification (Shanghai) Ltd. 10F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Zhabei District Shanghai 200436 CHINA</p> <p>Testing and Calibration Laboratory of Vibration and Noise of CSIC No.711 Research Institute No. 3111, Hua'ning Road, Shanghai, China</p> <p>Testing and Calibration Laboratory of Clause 14.6 of DEKRA Testing and Certification--WenZhou</p> <p>No.5, Changjiang Road, Great Bridge Industrial Park, North Baixiang, Wenzhou, 325603, China</p>								
<p>Summary of compliance with National Differences</p> <p>This tool is tested to and complies with EN 60745-1:2009 + A11:2010 and EN 60745-2-22:2011 +A11:2013 thus complying with the EU group differences.</p> <table> <tr> <td>Noise level:</td> <td>L_{pA}:104,0 dB(A)</td> <td>L_{wA}: 115,0 dB(A)</td> <td>K = 3 dB(A)</td> </tr> <tr> <td>Vibration level:</td> <td>a_h: 11,0 m/s²</td> <td>K = 1,5 m/s²</td> <td></td> </tr> </table>		Noise level:	L_{pA} :104,0 dB(A)	L_{wA} : 115,0 dB(A)	K = 3 dB(A)	Vibration level:	a_h : 11,0 m/s ²	K = 1,5 m/s ²	
Noise level:	L_{pA} :104,0 dB(A)	L_{wA} : 115,0 dB(A)	K = 3 dB(A)						
Vibration level:	a_h : 11,0 m/s ²	K = 1,5 m/s ²							

Copy of marking plate:



Marking labels of C355; CS355; CS14; SCS14; SCS355; SC14; SC355 are same as C14, only the models' names are different.

Test item particulars	
Class of tool	Class I
Method of supply cord attachment	Type Y
Duty conditions	Severe
Type of operation	Normal
Degree of protection	IPX0
Accessories and detachable parts included	-
Other options included	-
Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement	P (Pass)
- test object does not meet the requirement	F (Fail)
Testing	
Date of receipt of test item	2014-04-17
Date (s) of performance of tests	2014-04-18 to 2014-06-10
General remarks:	
<p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.</p>	
<p>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p>	
<p>The tools also tested and comply the following standards: IEC 60745-1:2006 IEC 60745-2-22:2011 EN 60745-1:2009+A11:2010 EN 60745-2-22:2011 +A11:2013 EN 62233:2008</p>	
Manufacturer's Declaration per sub-clause 6.2.5 of IEC 60745-1:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies)	LEE YEONG INDUSTRIAL CO., LTD. No.2, Kejia Rd., Douliu City, Yunlin County 64057, Taiwan
General product information:	
<p>This saw is designed exclusively for cutting masonry, stone, concrete, reinforced concrete and similar materials. All other uses are prohibited. C14; C355; CS355; CS14; SCS14; SCS355; SC14 and SC355 are the same, only the models' names are different. 110-120 V and 220-240 V version shares the same construction except the motors of them are different.</p>	

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

5	GENERAL CONDITIONS FOR THE TESTS		
5.2	A single tool subjected to all tests, except as specified, and it withstood all relevant tests		P
	A separate sample subjected to tests requiring tool modifications or disassembly after test performed		P
	Additional samples of tools designed for different supply voltages subjected to tests		N/A
	Testing of components necessitated subjecting additional samples of these components to tests		P
	Cumulative stress resulting from successive tests on electronic circuits avoided		N/A
	Components replaced or additional samples used as necessary		N/A
5.3	Tests conducted in order of clauses		P
	Tests specified not deemed applicable based on construction of the tool		N/A
5.4	The tool and its movable parts tested in most unfavourable position in normal use		P
5.5	User adjustable controls and switching devices tested in their most unfavourable settings		P
	Electronic speed control devices set at their highest speed		N/A
5.6	Tests conducted in a draught-free location, and unless otherwise specified, in (20 ± 5) °C		P
	Tests conducted at (23 ± 2) °C due to temperature limited temperature sensitive device		N/A
5.7.2	Tool rated for more than one rated voltage tested at the most unfavourable voltage (V)		P
5.8	Tool tested with attachments resulting in most unfavourable conditions		N/A
5.9	Tool tested with appropriate flexible cord, except as specified.....		N/A
5.10	Accessible metal parts of class I tools not connected to an earthing terminal checked for compliance with the appropriate requirements for class II construction		N/A
	Accessible non-metallic parts of class I tools checked for compliance with appropriate requirements specified for class II construction		N/A
5.11	Parts of tools class I or class II tools operating at safety extra-low voltage checked for compliance with requirements specified for class III tools		N/A
5.13	Heating element tested with the motor running		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Heating elements incorporated in the tool connected to a separate supply, unless otherwise specified		N/A
5.14	Attachments performing a function within the scope of a relevant parts 2, tested according to that part 2		P
	Other attachments tested in accordance with manufacturer's instructions		P
	In the absence of manufacturer's instructions, tool operated continuously using a load resulting in rated input or rated current (VA, A)		N/A
5.15	Tool loaded avoiding additional stresses such as side thrust when torque was to be applied		P
5.16	Tools operating at safety extra-low voltage and sold with their supply transformer tested using the supply transformer		N/A

7	CLASSIFICATION		
7.1	Tool is Class I, II, or III with respect to protection against electric shock	Class I	P
7.2	Degree of protection against harmful ingress of water per IEC 60529.....	-	N/A
	Required degree of protection other than IPX0 specified by manufacturer or in relevant part 2		N/A

8	MARKINGS AND INSTRUCTIONS		
8.1	Tool marked with rated voltage(s) or rated voltage range(s) (V).....	110-120 V 220-240 V	P
	Tool for star-delta connection clearly marked with the two rated voltages (e.g. 230 Δ / 400 Y V).....		N/A
	Nature of supply/frequency with symbol for nature of supply placed next to rated voltage (Hz).....	50-60 Hz	P
	Rated input or current marked (W or A)	110-120 V: 1700 W 220-240 V: 2800 W	P
	Rated input or rated current corresponds to highest loading possible for a tool with alternative components selectable by a control device		N/A
	Manufacturer's name, or trade mark, or identification mark and address of manufacturer or an agent responsible for marketing the tool.....	AGP No.2, Kejia Rd., Douliu City, Yunlin County 64057, Taiwan	P
	Model or type reference	C14; C355; CS355; CS14; SCS14; SCS355; SC14; SC355	P
	Class II symbol for class II tools.....		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	IP number other than IPX0.....:		N/A
	Tool provided with "WARNING – To reduce the risk of injury, user must read instruction manual" or the sign M002 of ISO 7010 ⁸)		P
	Additional markings not leading to misunderstanding permitted.....:		P
8.2	Rated operating time, or rated operating time and rated resting time, respectively, marked on a short-time or intermittent operation tool, except when operating time limited by construction of tool.....:		N/A
	Rated operating time precedes rated resting time, and they are separated by an oblique stroke.....:		N/A
8.3	Correct use of symbol for voltage ranges and different voltage levels.....:	110-120 V 220-240 V	P
8.4	Change in voltage clearly discernible		N/A
	Correct Wiring diagram fixed to tool		N/A
8.5	Rated power input		N/A
8.6	Use of correct symbols		P
	Correct dimensions and use for Class II symbol		N/A
	Other units and their symbols same as international standardised system		P
	No misunderstanding with use of additional symbols		P
8.7	A connection diagram affixed to a tool with more than two supply conductors, except when correct mode of operation is obvious as specified		N/A
	The earthing conductor not a supply conductor		N/A
	Wiring diagram indicates how the windings are to be connected for tools for star-delta connection		N/A
8.8	Terminals, except for type Z attachments, marked on non-removable part with specified symbols		N/A
	Terminal exclusively for neutral connection marked with "N"		N/A
	Earthing terminal marked with specified symbol		N/A
8.9	Switches, which may result in a hazard, marked accordingly using universally comprehensible symbol, or located to indicate which part of tool they control		N/A
8.10	"Off" position indicated by figure O of IEC 60417-5008 (DB:2002-10) when a hazard could result by unexpected start up		N/A
	Figure O not used for any other indication		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Position of moving contacts of mains switch correspond to indications for different positions of its operating means		N/A
8.11	Regulating devices and the like provided with markings as specified.....:		N/A
	Figures used for different positions with O for "off" position, and figures reflecting greater output for other positions		N/A
8.12	Instruction manual and safety instructions provided together with an explanation of the symbols.....:		P
	Instructions legible and contrasting in the official language(s) of the country where tool is sold, and include name and address of manufacturer, or supplier, or agent marketing the tool		P
8.12.1	Safety instructions in English are verbatim and in any other official language are equivalent	English manual	P
	Format of all Safety Warnings differentiate the context of all clauses by font or similar means and as illustrated in 8.12.1.1		P
8.12.1.1	General Power Tool Safety Warnings		P
8.12.1.2	Order of the Safety Instructions are in accordance with this clause		P
8.12.2	Warnings required by this clause included in Instruction Manual when Safety Instructions are separate from instruction Manual		N/A
	Warnings in English are verbatim and in any other official language are equivalent.....:		P
	Instruction Manual provided with the required information in a) to d) of this clause as appropriate		P
8.13	Markings easily legible and withstood durability test		P
	Signs are in contrast to their background, clearly legible from a distance of not less than 500 mm		P
	Label material, grade designation, ink and printing process		P
	Signs complied with blue colour requirements of ISO 3864-2		N/A
8.14	Markings in 8.1 to 8.5 on a main part of the tool		P
	Markings in 8.1, 8.2, 8.3, and 8.5 placed together		P
	Markings clearly discernible from outside of the tool, but if necessary, after removal of a cover without aid of a tool		P
	Indications for switches and controls placed on or in vicinity of components		P
8.15	Thermal link or fuse-link marked appropriately		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

9	PROTECTION AGAINST ACCESS TO LIVE PARTS		
9.1	Accessible part not considered live		N/A
	- extra-low a.c. voltage: peak values not exceeding 42.4 V		N/A
	- extra-low d.c. voltage: not exceeding 42.4 V		N/A
	- or separated from live parts by protective impedance, d.c. current not exceeding 2 mA	See appended Table 9.1	N/A
	- or separated from live parts by protective impedance, a.c. peak value not exceeding 0.7 mA	See appended Table 9.1	N/A
	- for peak value 42.4 V up to and including 450 V capacitance not exceeding 0.1 μ F	See appended Table 9.1	N/A
	- for peak value 450 V up to and including 15 kV capacitance not exceeding 0.1 μ F	See appended Table 9.1	N/A
9.2	Probe of Fig 1 did not contact live parts with detachable parts removed		P
	Probe of Fig 1 did not contact live parts of the lamp with detachable parts removed		N/A
	Screw type fuses or screw-type miniature circuit breakers accessible without aid of a tool excluded from this requirement		N/A
	Probe of Fig 1 did not contact live parts or live parts protected only by lacquer, enamel, ordinary paper, cotton, oxide film, beads, or sealing compound applied through an opening with 20 N force		P
9.3	Test pin of Fig 2 did not contact live parts, through openings in class II tools or class II constructions		P
9.4	Probe of Fig 1 did not contact basic insulation through openings in Class II tools or Class II constructions with all detachable parts removed		P

10	STARTING		
10.1	Motors start under normal voltage conditions		P
	Starting ten times at 0.85 times rated voltage without load (V)	187 V	P
10.2	Centrifugal and other automatic starting switches operated reliably 10 times at 1.1 of the rated voltage (V)		N/A
10.3	Overload protection devices did not operate under normal starting conditions as confirmed by 10.1 and 10.2		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
11	INPUT AND CURRENT		
11.1	Marked power input or current is at least 110% of measured no-load input or current.....:	See appended Table 11.1	P
12	HEATING		
12.1	Excessive temperatures not attained under normal load	See appended Table 12.1	P
	Measurements for heating elements repeated as specified		N/A
12.2	Loading conditions during temperature test.....:	See appended Table 12.1	P
	Heating elements tested to IEC 60335-1 at 1.06 times rated voltage		N/A
12.3	When possible, temperature rises of uniform windings determined by resistance method.....:	See appended Table 12.3	P
	Temperature rise of electrical insulation, other than windings, measured on surface of insulation.....:		P
12.4	Tool operating time.....:	See appended Table 12.1	P
12.5	Temperature rises did not exceed values in Table 1, except as allowed by 12.6		P
	Protective devices did not operate		N/A
	Sealing compounds did not flow		P
12.6	When winding temperatures exceeded values in Table 1, three additional samples successfully subjected to following tests:		N/A
	a) Heat treatment for 240 h at the specified cabinet temperature (°C):.....:		N/A
	b) No inter-turn short circuit after oven treatment		N/A
	c) Humidity treatment in accordance with 14.3		N/A
	d) No excessive leakage current after humidity treatment.....:	See appended Table 13.1B	N/A
	No flashover or breakdown occurred during electric strength after humidity treatment	See appended Table 15.2A	N/A
13	LEAKAGE CURRENT		
13.1	Leakage current was not excessive	See Tables 13.1A-13.1D	P
	Protective impedance disconnected		N/A
13.2	Leakage current measured using circuit of Fig. 10		P
14	MOISTURE RESISTANCE		
14.1	Degree of protection for tool enclosure according to tool classification (IP Code).....:		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
14.1.1	Tool not connected to the supply and turned continuously through most unfavourable positions		N/A
	Lightest permissible flexible cord with smallest cross-sectional area specified on Table 8 used on the tool with type X attachment (A, mm ²).....:		N/A
	Other tools tested as delivered		N/A
14.1.2	Tool rated IPX1 through IPX7 subjected to applicable tests of IEC 60529		N/A
	For IPX7 test, tool immersed in water containing 1.0 % NaCl		N/A
	Tool withstood electric strength test of 15 after moisture treatment	See appended Table 15.2B	N/A
	No trace of water on insulation causing reduction of creepage and clearance below values in 28.1		N/A
14.2	No trace of water on insulation causing reduction of creepage and clearance below those in 28.1 after spillage of liquid test		N/A
	Tool withstood electric strength test of 15 after spillage treatment	See appended Table 15.2B	N/A
	Tool subjected to test of 14.3 after standing in normal test –room atmosphere for 24 h		N/A
14.3	Tool subjected to humidity treatment test for 48 h	48 h	P
	Relative humidity (93 ± 2) %	93%	P
	Temperature (20 - 30 °C ± 1K)	25 °C	P
	No excessive leakage after humidity treatment.....:	See appended Table 13.1C	P
	No flashover or breakdown occurred during electric strength after humidity treatment	See appended Table 15.2B	P
14.4	User not subject to an increased risk of electrical shock by liquid system during foreseeable use		P
	Tool operated for 1 min in each mode and did not exceed maximum allowed leakage current	See appended Table 13.1D	P
	Tool did not exceed maximum allowable leakage current after drying for 24 h at ambient temperature	See appended Table 13.1D	P
14.5	Liquid system withstood the pressure in normal use without leaking		P
	Tool did not exceed maximum allowable leakage current during pressure application	See appended Table 13.1D	P
	Tool did not exceed maximum allowable leakage current after drying for 24 h at ambient temperature	See appended Table 13.1D	P
14.6	Residual current devices complied with IEC 61540 and met requirements a) to c)		P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	a) RCD disconnected only both mains conductors when leakage exceeded 10 mA with a maximum response of 300 ms		P
	Test conducted according to 9.9.2 of IEC 61540, and earthing conductor stayed connected		P
	b) RCD operated correctly for all 50 cycles		P
	c) RCD cannot be removed during use or routine normal maintenance (i.e., residual current device fixed to tool or power supply cord connected to tool)		P
	RCD fitted in supply cord provided with Type Y or Z attachment for connection to supply cord and interconnecting cord	Type Y	P

15	ELECTRIC STRENGTH		
15.1	Protective impedance disconnected		N/A
15.2	No flashover or breakdown occurred during the test with the output current at least than 200 mA and the applied measured voltage +/- 3%	See Tables 15.2A-15.2E	P
	The insulation coating withstood the applied potential with the 5 kPa force applied		N/A
	For the tool with integral heating elements, test voltages specified in IEC 60335-1 applied to the heating elements only and not to other parts of tool		N/A

16	OVERLOAD PROTECTION OF TRANSFORMERS AND ASSOCIATED CIRCUITS		N/A
----	--	--	-----

17	ENDURANCE		
17.1	No hazards due to extended normal use		P
17.2	No load intermittent operation (2 x 24 h)		P
	Number of operations.....	2	—
	Number of hours for each operation	24	—
	Test voltage at each operation (V)	132 V/ 99 V 264 V/198 V	—
	Rate of operation (100s “on”, 20s “off”)	100s “on”, 20s “off”	—
	Test positions selected	3 positions	—
	Operation time for each position	8	—
	Servicing of carbon brushes and lubricant.....		N/A
	Forced cooling or rest periods if temperature exceeded values in Table 1		N/A
	No electrical or mechanical failure		P
	No insulation damage		P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	No loose contacts or connections		P
	No flashover or breakdown occurred after spillage treatment.....:	See Table 15.2C	P
	No operation of overload protection devices		N/A
17.3	Tools with Centrifugal switches operated for 10,000 cycles		N/A
	Number of operations under normal load		N/A
	Rate of operations (s "on", s "off").....:		N/A
	Test voltage 0.9 x rated Voltage (V).....:		N/A
	No electrical or mechanical failure		N/A
	No insulation damage		N/A
	No loose contact or connections		N/A
	No flashover or breakdown occurred.....:	See Table 15.2D	N/A
	No opening of overload protection devices		N/A

18	ABNORMAL OPERATION		
18.1	No hazard due to abnormal operation		P
	Fuses, thermal cut-outs, over current protection devices used to provide the necessary protection		N/A
18.2	Tool with heating elements		N/A
	Tool with a control device limiting temperature.....:		N/A
	Only one abnormal condition simulated each time		N/A
	Tests of Clauses 18.2-18.6 conducted consecutively when more than one test applicable to the same tool		N/A
	Tool tested until a non-self-resetting thermal cut-out operated, or until steady conditions.....:		N/A
	Test repeated on a second sample when a heating element permanently open-circuited		N/A
	Only one abnormal condition simulated each time		N/A
18.3	Tool with heating elements tested under the conditions of heating test, except with restricted heat dissipation		N/A
	Test voltage provided a power 0.85 times rated power input (V)		—
18.4	Tool cooled down to room temperature and test of 18.3 repeated		N/A
	Test voltage provided a power input of 1.24 times rated power input (V)		—
18.5	Tested as in heating test, under normal operation with control limiting the temperature short-circuited		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Test voltage provided a power input of 1.15 times rated power input (V)		—
	Multiple controls short-circuited one at a time		N/A
18.6	Test on class I tool with tubular sheathed and embedded heating elements		N/A
	Test repeated with the supply polarity reversed and other end of element connected to earth		N/A
18.7	No load test for 1 min on cutting tools incorporating a commutator motor		P
	Test voltage 1.3 times rated voltage, or upper limit of voltage range (V)	240 V x 1,3=312 V 120 V x 1,3=156 V	—
	After the tests of 18.2 to 18.7, safety of tool not impaired, and windings and connections not loose		P
18.8	Test on tools with induction motor and with moving parts locked		N/A
	a) Tool with a starting torque less than full-load torque		N/A
	Duration of locked conditions (s)		—
	b) Tool started by hand		N/A
	Duration of locked condition (s)		—
	c) tool with moving parts liable to be jammed, or moving parts that can be stopped by hand with the motor switched on		N/A
	Duration of locked condition (s)		—
	After the test, or at the instant of operation of fuses, thermal cut-outs, motor operated devices, and the like, the temperature of the windings complied with the values in Table 3		N/A
	Max winding temperature recorded (°C)		—
18.9	Test on tools with 3-phase motors with one phase disconnected		N/A
	30 s tests for tool switched on by hand or continuously loaded by hand; cold started		N/A
	5 min test for other tools		N/A
	After the test, or at the instant of operation of fuses, thermal cut-outs, motor protection devices, and the like, the temperature of the windings complied with the limits in Table 3		N/A
	Max winding temperature recorded (°C)		—
18.10	No hazards occurred under fault conditions of 18.10.2		P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Circuits complied with 18.10.1 and not subjected to fault conditions of 18.10.2		N/A
	Test of 18.10.3 conducted when safety of tool under a fault condition depended on operation of a miniature fuse-link complying with IEC 60127-3		N/A
	Tool withstood the particular test as a conductor of a PCB open-circuited, and		N/A
	– base material of PCB withstood test of Annex F,		N/A
	– creepage or clearances between live parts and accessible metal parts not reduced below values in 28 due to loosened conductors, and		N/A
	– tool withstood tests of 18.10.2 with the open-circuited conductor bridged		N/A
18.10.2	Fault conditions a) to f) conducted as applicable	See Table 18.10.2	N/A
18.10.3	Tests repeated with fuse-link replaced by an ammeter when during fault conditions of 18.10.2, safety of the tool depended on operation of a miniature fuse-link complying with IEC 60127-3,	See Table 18.10.2	N/A
	– Circuit not considered to be adequately protected when current measured was ≥ 2.1 times the rated current of fuse-link, and test conducted with fuse-link short-circuited (A)		N/A
	– Circuit considered adequately protected when current measured was ≥ 2.75 times the rated current of fuse-link (A)		N/A
	– Fuse-link short-circuited when current measured was 2.1-2.75 times the rated current of fuse-link, and test conducted as follows (A)		N/A
18.10.4	Tools incorporating electronic devices are so designed that no hazard results in the event of a failure in the electronic equipment	See Table 18.10.2	P
	Tool operated for 1 min, at a voltage equal to the rated voltage or the mean value of the voltage range, at no-load with the electronic device short-circuited.		P
	No hazard resulted when test repeated with electronic device open-circuited		P
	No damage due to fire and mechanical damage impairing safety and protection against electric shock following the tests of 18.10.1 to 18.10.4, and		P
	- Current through protective impedance was less than limits of Clause 9.1 (A)		N/A
	Tool considered to have withstood the test when speed-limiting device operated		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
18.11	Switches and devices for motor reversal withstood stresses occurring when rotation reversed 25 times under running conditions at rated voltage or upper limit of rated voltage range at no-load (V).....:		N/A
18.12	Class I tool with class II construction and class II tool operated under extreme overload conditions without impairing protection against electric shock		P
	A separate sample operated for 15 min, until the tool open-circuited, or flame appeared	Open-circuited	P
	Test circuit (KVA).....:	20 kVA	—
	160% normal load test current (A)	240 V: 18,9 A 120 V: 24,0 A	—
	Overload condition existed for (_min, _sec)	240 V: 3 min 29 sec 120 V: 15 min expired	—
	Condition continued until the tool open-circuited, or flame appeared or 15 minutes expired	240 V: Open-circuited	P
	Elements that opened in case an open circuit occurred.....:		N/A
	When flames appeared, immediately extinguished by CO ₂ extinguisher		N/A
	Maximum leakage current measured throughout the abnormal test (mA).....:	See Table 13.1D	P
	Tool that did not operate after 15 min, cooled to room temperature and subjected to a 1500 V Electric Strength test (live parts and accessible parts).....:	Live parts and accessible parts:1500 V	P
	Tool that operated after 15 min, cooled to room temperature and subjected to a 2500 V Electric Strength test (live parts and accessible parts).....:	-	P

19	MECHANICAL HAZARDS		
19.1	Adequate protection against injury provided against moving and dangerous parts		P
	Protective enclosures, covers, and the like have adequate mechanical strength and cannot be removed without the aid of a tool		P
	No dangers from adjusting the guards		P
	No dangers due to movement or release of working elements during normal use		P
	No contact with dangerous moving parts using standard test finger (Fig 1)		P
19.2	No sharp edges, burrs, flashes and the like		P
19.3	No contact of moving parts with test finger (Fig 1) with removal of dust collection system		P
19.4	Adequate grasping surfaces		P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
19.5	Provision for visual checking of the contact of cutting tool with work piece		P
19.6	The no-load speed of the spindle did not exceed 110 % of the rated no-load speed	See part 2	N/A

20	MECHANICAL STRENGTH		
20.1	Adequate mechanical strength in normal use		P
	No flashover or breakdown occurred after tests of 20.2-20.4 and 15	See Table 15.2E	P
	No damage impairing compliance with this standard, and no live parts became accessible		P
20.2	Three blows applied to every weak point of enclosure by spring-operated impact test apparatus in Clause 5 of IEC 60068-2-75		P
	Brush cap impact energy (Nm)	-	—
	Other part impact energy (Nm)	1,0 Nm	—
	Blows applied to protective devices, handles, levers, and knobs when necessary.....	Handle, knob, enclosure(air inlet)	P
	No damage impairing compliance with standard		P
	No accessibility of live parts		P
	No cracks visible to naked eye		P
	Inner cover withstood test		N/A
20.3	Hand-held tool withstood impact of 3 varied drops on a concrete surface from 1 m		P
	No damage impairing compliance with standard		P
	No accessibility of live parts		P
	No cracks visible to naked eye		P
	Inner cover withstood test		N/A
20.4	Adequate mechanical strength of brush holder and their caps		N/A
	Brush cap removed and replace 10 times applying specified tightening torque		N/A
	Tightening torque (Nm)	-	—
	No damage impairing compliance with standard		N/A
	No accessibility of live parts		N/A
	No cracks visible to naked eye		N/A
	No damage to threads		N/A
20.5	Handles and grasping surfaces have adequate mechanical strength to provide insulation between grasping area and output shaft		P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	A separate sample subjected to a single impact from 1m onto a concrete surface on each handle and each recommended grasping surface followed by an electric strength test of 1250 V a.c.		P
	No damage impairing compliance with standard		P
	No accessibility of live parts		P
	No cracks visible to naked eye		P
	No flashover or breakdown of insulation	See Table 15.2E	P

21	CONSTRUCTION		
21.1	Accidental changing of setting did not occur in tools with different voltages or different speed settings		N/A
21.2	Accidental changing of settings of control devices did not occur		N/A
21.3	Removal of parts ensuring required degree of protection against moisture not possible without aid of a tool		N/A
21.4	Fixing of handles, knobs and the like, used to indicate position of switches or similar components in a wrong position, was not possible		P
21.5	Replacement of a flexible cable or cord requiring displacement of a switch was possible without subjecting internal wiring to undue stress		P
	After repositioning of the switch and before reassembling the tool, verification of correct positioning of internal wiring was possible		P
21.6	Wood, cotton, silk, paper and similar fibrous or hygroscopic material not used as insulation, unless impregnated or chemically rendered non-fibrous		N/A
21.7	Asbestos not used		P
21.8	Ordinary driving belts not relied upon to ensure electrical insulation		N/A
	Special belt design employed to allow use as electrical insulation		N/A
21.9	Insulating barriers of Class II tools, and parts of Class II tools serving as supplementary or reinforced insulation are:		N/A
	- fixed such that they cannot be removed without being seriously damaged		N/A
	- so designed that they cannot be replaced in an incorrect position, and when omitted, the tool will be inoperable or manifestly incomplete		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
21.10	Use of the sheath (jacket) of a flexible cable or cord as supplementary insulation inside the tool is independent of mechanical and thermal stresses		N/A
21.11	No assembly gap with a width greater than 0.3 mm in supplementary insulation giving access to live parts		P
21.12	No hazards from parts of Class I tool such as wire, screw, nut, washer or spring becoming loose or falling out of position, and accessible metal not made live		P
	Clearance and creepage distances of Class II tool or class II construction not reduced to less than 50% of values shown in Table 10		N/A
	Class II tool or Class II construction, other than those of the all-insulated type, provided with an insulating barrier between accessible metal and motor parts and other live parts		N/A
	Class I tool with adequately fixed parts, barriers, and sufficiently large creepage and clearances		P
	All wires secured in place independent of terminal connection or solder		P
21.13	Supplementary and reinforced insulation not impaired by deposition of dirt, or dust resulting from wear of parts within the tool to the extent that creepage and clearances would be reduced		P
	Ceramic material not tightly sintered and similar materials, and beads alone, not used as supplementary or reinforced insulation		N/A
	Parts of natural or synthetic rubber used as supplementary insulation are resistant to aging		N/A
	Rubber parts so arranged and dimensioned that creepage distances not reduced below values in 28.1, even when cracks occurred		N/A
	Insulated material for embedded heating conductors serves only as basic insulation		N/A
	Aging test for rubber parts for 70 h at 100±2°C		N/A
	Rubber parts tested.....: -		—
21.14	Internal wiring, windings, and the like including insulation in general not exposed to oil, grease, and similar substances		P
	Adequate insulation properties of oil, grease, and similar substances used for lubrication of gears and the like with no effect on insulation		P
21.15	No access to brushes without aid of a tool		P
	When tightening screw-type brush-caps, two surfaces clamped together		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Locking device retaining brushes in position do not depend upon brush spring tension		P
	Screw-type brush-caps accessible from the outside of the tool made of or covered with insulating material of adequate strength, and not projecting beyond surrounding surface of the tool		N/A
	Properties of insulating materials		N/A
	– tested according to Cl. 20.2 and 20.4 for screw-type brush-caps accessible from outside of tool		N/A
	– tested as specified for supplementary insulation for class I and class III tools		N/A
	– tested as specified for reinforced insulation for class II tools		N/A
21.16	Tool employing a liquid system protects the user against increased risk of shock due to presence of liquid under normal use and faults of liquid system		P
	Tools employing liquid system constructed as Class III tools, or		N/A
	- class I or II and provided with a residual current device, and complying with 14.4-14.6, or		P
	- class I or class II and designed for use in combination with an isolating transformer and complying with 14.4 and 14.5		N/A
21.17	Accidental operation of switches and reset buttons on non-self-resetting controls did not occur when tool dragged across a horizontal surface		P
21.18	Tools, other than those provided with a flexible shaft, fitted with a mains switch which can be switched off by the user without releasing the grasp on the tool		P
	A switch locking in “on” position considered to meet the requirement of 21.18, provided it unlocks automatically when the trigger or actuating member is activated		N/A
21.18.1	Switch could not be locked in “on” position and did not remain in “on” position after trigger released when a risk with continued operation existed		P
21.18.2	Switch was locked in “off” position when a risk associated with inadvertent starting existed		P
21.19	Protection against electrical shock not affected when screws accessible from the outside replaced by longer screws simulating routine servicing		P
	Creepage and clearances not reduced below values in 28.1		P
21.20	Tool marked with the first numeral of IP system complies with IEC 60529.....:		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
21.21	No risk of electrical shock from charged capacitors when touching pins of the plug		P
	Max. voltage measured between pins of the plug after one second after each disconnection (V)	0 V	P
	Line capacitors rated $\leq 0.1 \mu\text{F}$		N/A
21.22	Non-detachable parts secured reliably and withstood mechanical stress under normal use		P
	Snap-in devices have an obvious locked position and have fixing properties that do not deteriorate		N/A
	Parts disassembled and assembled 10 times prior to test showed no signs of deterioration		N/A
	Parts affected by temperature tested immediately after conditions of Clause 12		N/A
	All weak parts of the tool subjected to the 10 s push force of 50 N		N/A
	50 N pull force applied to cover or weak part when shaped prevented easy slippage of fingertips		N/A
	30 N pull force applied to cover or weak parts when projection of the gripped part was less than 10 mm in the direction of removal		N/A
	Test fingernail of Fig. 7 inserted in apertures and joints with a force of 10 N to enable a force of 30 N for 10 s by means of a loop while applying push/pull forces		N/A
	A torque of 2 Nm applied at the same time as pull or push force on parts 50 mm or smaller and likely to be subjected to twisting,		N/A
	A torque of 4 Nm applied at the same time as pull or push force on parts larger than 50 mm and likely to be subjected to twisting,		N/A
	Projection was less than 10 mm and required a torque of (Nm)		N/A
	Parts not detached, and remained in locked position		N/A
21.23	Handles, knobs, etc., withstood axial force of 30 N for 1 minute		P
21.24	Storage hooks and similar devices for flexible cords are smooth and well rounded		N/A
21.25	Current-carrying parts and other parts resistant to corrosion under normal use		P
	After tests of Clause 30, no sign of corrosion on relevant parts		N/A
21.27	Insulation between SELV and other parts of non-class II tool meets requirements for double or reinforced insulation		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
21.28	Parts separated by protective impedance comply with requirements for double or reinforced insulation		N/A
21.30	Shafts of operating knobs, handles, levers, and the like not live, except when removal of such parts does not make the shaft accessible to test finger		P
21.31	Handles, levers, and knobs of non-class III tool held or actuated in normal use do not become live during an insulation fault		P
	Metallic handles, levers, and knobs with shaft and securing means likely to become live due to basic insulation fault, adequately covered by insulating material or their accessible parts separated from their shafts or securing means by insulation		P
	Covering or insulating material complies with Electric Strength test in Clause 15, Table 2, item 4		P
21.32	Tool likely to cut into concealed wiring or cord, has handles and grasping surfaces made of insulating material, or metal covered by insulating material, or their accessible parts are separated by insulating barrier(s) from accessible metal parts that may become live by the output shaft		P
	Insulated, stick type, auxiliary handle is provided with a flange \square 12 mm high above grasping surface between grasping area and accessible parts that may become live by the output shaft		N/A
21.33	Capacitors in class II tools not connected to accessible metal parts, and their metallic casings are separated from accessible metal parts by supplementary insulation		N/A
	Capacitors tied to accessible metal parts comply with Clauses 9.1 and 21.36		N/A
21.34	Capacitors not connected between contacts of the thermal cut-outs		N/A
21.35	Lamp holders used only for connection of lamps		N/A
21.36	Protective impedance consists of at least two separate components with impedance unlikely to change significantly during lifetime of tool		N/A
	When a component short or open-circuited, values in Clause 9.1 were not exceeded		N/A
	Resistors comply with 14.1 of IEC 60065 and capacitors comply with 14.2 of IEC 60065		N/A
21.37	Air-intake ventilation openings not excessively large		P
	It was not possible to insert a steel ball 6 mm in diameter through air-intake openings other than those adjacent to fan		P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
22	INTERNAL WIRING		
22.1	Wireways smooth and free from sharp edges, burrs, etc.		P
	Holes in metal through which insulated wires pass provided with bushings or, except as required by relevant part 2, have smooth, well-rounded edges with a radius of 1,5 mm		N/A
	Wiring prevented from coming into contact with moving parts		P
22.2	Internal wiring and electrical connections adequately protected or enclosed		P
22.3	Internal wiring adequately rigid, fixed or insulated such that, in normal use, creepage and clearances cannot be reduced below values in 28.1		P
	The insulation not damaged in normal use		P
	Insulation of internal wiring electrically equivalent to insulation of cords complying with IEC 60227 or IEC 60245		N/A
	No breakdown resulted upon application of a 2000 V electric voltage for 15 min between conductor and metal foil wrapped around insulation		P
	Sleeves used as supplementary insulation on internal wiring remain in position by clamps at both ends requiring its removal by breaking or cutting		N/A
22.4	Use of green/yellow conductors for earthing terminals only		P
22.5	Aluminium wires not used for internal wiring		P
22.6	Stranded conductors with lead-tin soldering are only used with spring terminals with constant contact pressure, except when clamping means pose no risk of bad contact		N/A

23	COMPONENTS		
23.1	Components comply with relevant IEC standards	See appended Table 23.1	P
	Components used in accordance with their markings		P
	Applied exceptions		N/A
23.1.1	Capacitors in auxiliary windings of motors marked with their rated voltage and rated capacitance		N/A
23.1.2	Fixed capacitors for radio interference suppression comply with IEC 60384-14		P
23.1.3	Small lamp holders similar to E10 lamp holders meet requirements for E10 lamp holders		N/A
23.1.4	Insulating and safety insulating transformers comply with IEC 61558-1		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
23.1.5	Appliance couplers other than those used for IPX0 tools comply with IEC 60309, and those used for IPX0 comply with IEC 60320		N/A
	Instructions provided to inform user to connect the tool with non-IEC appliance couplers		N/A
23.1.6	Automatic controls not complying with IEC 60730-1 tested according to this standard, and additionally according to 11.3.5 – 11.3.8 and 17 of IEC 60730-1		N/A
	IEC 60730-1 tests conducted under conditions occurring in the tool		N/A
	Type of controls used and number of operations completed per Cl. 17 of IEC 60730-1 (cycles).....:		N/A
	Correct markings used on automatic controls		N/A
	Tests of Clause 17 of IEC 60730-1 were not conducted on automatic controls because tool complies with this standard when protective device short-circuited		N/A
	Thermostats and temperature limiters tested in accordance with a specific exception in footnote b) of Table 1 of Clause 12		N/A
23.1.7	Unless otherwise specified, tests on components per other standards conducted separately according to the relevant standard		N/A
	Component, marked and used per its markings		N/A
	Components not mentioned in Table 1 of Clause 12 tested as part of the tool		N/A
23.1.8	If no IEC standard, or when component not marked or used not as marked, component tested under conditions occurring in the tool, and number of samples as required by similar specifications.....:		N/A
23.1.9	Capacitor voltage did not exceed 1.1 times its rated voltage (V)		N/A
23.1.10	Adequate breaking capacity of mains switches with no electrical mechanical failure		P
	Mains switches rated for min. 50K cycles of operations	50 000	P
	Switch operated 50 times with motor stalled		P
	For electronic control device switching off before opening the main contacts, switch operated five times with the electronic device short-circuited		N/A
23.1.11	Switches, not separately tested and found to comply with IEC 61058-1 under the conditions occurring in the tool, comply with Annex I		N/A
	Test of 17.2.4.4 of IEC 61058-1 conducted for a min. of 50000 cycles of operation		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Switches operated only with the aid of a tool and intended for no load operation were not subjected to tests of Clause 17 of IEC 61058-1		N/A
	The above also applied to switches operated by hand and interlocked not to be operated under load		N/A
	Switches without interlock tested per IEC 61058-1, 17.2.4.4 for a min. of 100 cycles of operation.....:		N/A
	Tests of 17.2.4.4 of IEC 61058-1 not conducted on a switch when tool met the requirements of this standard when the switch short-circuited		N/A
23.2	Tool not fitted with switches or automatic controls in flexible cords		P
	Tool not fitted with devices causing the protection device in the fixed wiring to operate		N/A
	Tool not fitted with thermal cut-outs which can be reset by a soldering operation		N/A
23.3	Overload protection devices are non-self-resetting		N/A
23.4	Plugs and socket-outlets used as terminal devices for heating elements and plugs and socket-outlets for ELV circuits not interchangeable with plugs and socket-outlets in IEC 60884, and with connectors and tool inlets complying with IEC 60320		N/A
23.5	Motors connected to the supply mains with insulation inadequate for the rated voltage comply with Annex B		N/A

24	SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CORDS		
24.1	Tool rated in voltage or frequency for connection to public supplies provided with a supply cord with a plug		P
	Tool intended to be connection to non-public power supplies provided with a supply cord without a plug		N/A
	Tool provided with appliance inlet for connection to a supply having at least same degree of protection against moisture as required for the tool, and with locking device preventing accidental disconnection		N/A
	Tool provided with a supply cord for connection to a supply ≤ 0.5 m and fixed with an in-line connector (cable coupler) and its mating counterpart		N/A
	The in-line connector provided with at least the same degree of protection against moisture as required for the tool		N/A
	Locking devices complied with pull test of 24.14		N/A
24.2	Supply cord assembled to the tool by attachment type (specify X, Y, or Z)	Type Y	P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Supply cord with type X and type Y attachment is ordinary flexible cord or a special cord only available from the manufacturer or its agent.....:	ordinary	P
	Special cord includes part of the tool		N/A
24.3	Plugs fitted with only one flexible cord		P
24.4	Supply cord not lighter than ordinary tough rubber sheathed flexible cord or ordinary PVC sheathed flexible cord		P
	PVC cords not used if external metal parts exceed 75 K temperature rise		N/A
	Power supply cords of single-phase tool with a plug and rated current ≤ 16 A supplied with a plug complying with IEC 60884 or IEC 60309		P
	Class I tools fitted with plugs complying with IEC 60309, Sheet 2-1		P
	Class II tools fitted with plugs complying with IEC 60309, Sheet 2		N/A
	Class III tools fitted with plugs complying with IEC 60309, Sheet 2-1		N/A
	Body of plug covered with, rubber, polyvinyl chloride, or a material with equivalent mechanical strength ...:		P
	Supply cords of class I, single-phase tool rated > 16 A ≤ 63 A, and multi-phase tool rated ≤ 63 A, provided with a plug complying with IEC 60309 and standard Sheet 2-III based on current		N/A
	Supply cords of class II, single-phase tool rated > 16 A ≤ 63 A, and multi-phase tool rated ≤ 63 A, provided with a plug complying with IEC 60309 and standard Sheet 2		N/A
	Supply cords of class III, single-phase tool rated > 16 A ≤ 63 A, and multi-phase tool rated ≤ 63 A, provide with a plug complying with IEC 60309 and standard Sheet 2-III		N/A
24.5	Nominal cross-section area of supply cord per Table 6 (mm^2).....:	1,5 mm^2	P
24.6	Supply cord of class I tool has green/yellow core connected to internal earthing terminal of the tool, and to earthing contact of plug		P
24.7	Lead-tin solder not used to consolidate leads under pressure, except when clamping means used prevent risk of a bad contact		N/A
	Clamping screws alone not used for securing soldered leads		N/A
24.8	Moulding supply cord to any part has no effect on the insulation of the cord		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
24.9	Inlet openings provided with a bushing, or no risk of damaging protective covering of supply cord		P
24.10	Inlet bushings shaped to prevent damage to supply cord		P
	Inlet bushings reliably fixed and not removable without the aid of a tool		P
24.12	Cord guards provided with adequate mechanical strength and retain these properties throughout extended normal use		P
	Flexing test performed in apparatus shown in Fig. 9		P
	Weight attached to cable or cord (kg).....:	6 kg	—
	Oscillating member moved backwards and forwards through an angle of 90° (45° on either side of the vertical) with rate of flexings 60/minute		P
	After 10,000 flexings, sample turned through 90° about the centre of the cord guard		P
	After the test, cord guard not loosened, and no damage to cord guard and flexible cable impairing compliance with this standard	0%	P
	Number of strands versus number of broken strands of each conductor not more than 10%.....:		P
	Cord guard did not slip out from its location after completion of ten 1 sec lifts		P
24.13	Cord guard of insulating material provided to protect against excessive bending at inlet opening		P
	Guard fixed reliably and projects outside tool a distance beyond inlet opening of at least 5 times the overall diameter of cable or cord		P
	Cord guard integral to tool minimum 100 mm longer than guard		P
	Mass attached to the free end of cable or cord (g) ..:	1188 g	—
	Temperature sensitive cord guard tested at 23±2°C		N/A
	Curvature of cable or cord is nowhere less than 1.5 of external diameter of cable		P
24.14	Conductors relieved from strain, twisting and protected from abrasion		P
	It is not possible to push the cord into the tool		P
	Pull force was applied 25 times at the force prescribed in Table 7 (N).....:	100 N	—
	After pull test, cord, other than automatic cord reel, subjected to torque in Table 7 for 1 min (Nm)	0,35 Nm	P
	The cord was not damaged during the tests		P
	Cord longitudinal displacement (mm)	0 mm	P

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Conductors movement in the terminals (mm):	0 mm	P
	No appreciable strain at the connection		P
	Creepage and clearances not reduced below values in Cl. 28.1		P
24.15	Cord anchorage either accessible only with the aid of a tool, or the cord can only be fitted using a tool		P
24.16	Cord anchorage for type X attachment		N/A
	Cord anchorage allows easy replacement of cord		N/A
	It is evident how strain relief and prevention of twisting are accomplished by the cord anchorage		N/A
	Anchorage is suitable for different types of cord, or tool designed to be fitted with only one type of cord		N/A
	Cord anchorage screws separated by supplementary insulation		N/A
	Cord is not clamped by metal screw bearing directly on the cord		N/A
	At least one part of cord anchorage securely fixed to the tool, unless it is part of the specially prepared cord		N/A
	Screws intended to fix the cord in place are not used to secure any other part, or it is clear the tool is inoperative		N/A
	Parts fastened to the cord anchorage by the same screw could not be removed without the aid of a tool		N/A
	Cord anchorage is such that in case of labyrinths, the labyrinths cannot be bypassed in a way that the requirement of Clause 24.14 is not met		N/A
	For type X attachment, gland not used as cord anchorage for power supply cord		N/A
	Cord anchorage in class I tool is of insulating material or provided with an insulating lining		N/A
	Cord anchorage in class II tool is of insulating material, and when metallic, meet requirements for supplementary insulation		N/A
	Type X has one or more nuts to secure cord anchorage to tool		N/A
	Clamping member complies with Figure 6		N/A
	Tests of Cl. 24.14 conducted with lightest type of cord of smallest cross-section and next heavier type as in Cl. 25.2 (sizes, mm ²):	1,5	P
	Specially prepared cord tested with the cord as delivered		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Conductors inserted into terminals, terminal screws tightened sufficiently to prevent conductors from easily changing their position, torque set at	0,53 Nm	P
24.17	Adequate cord anchorages are provided for type Y and Z attachments and complied with 24.14		P
24.18	Knots and tying strings for type X attachment are not used		N/A
24.19	The insulated conductors of the supply cord are insulated from accessible metal parts by basic insulation for class I tool, and supplementary insulation for class II tools		P
	- insulation consists of a separate insulating lining fixed to cord anchorage		P
	- a sleeve or grommet is fixed to the cord		N/A
	- for class I tools, insulation consists of sheath of the sheathed cord		P
24.20	For type X attachment space for supply cables or supply cord provided inside or as a part of tool		N/A
	- space permits verification of correct connection and positioning of conductors		N/A
	- space permits covers to be fitted without risk of damage to supply conductors or their insulation		N/A
	- uninsulated end of conductor, when detached from a terminal, cannot come into contact with accessible metal parts		N/A
	Installation test conducted with cables or flexible cords of the largest cross-sectional area as per Clause 25.2 (mm ²)		N/A
	For pillar terminals (with conductors that are not separately clamped 30 mm or less from terminal), and for other terminals with screw clamping, a force of 2 N applied to the wire in any direction and adjacent to the terminal, screw or stud		N/A
	The uninsulated end of the conductor did not come into contact with accessible metal parts		N/A
24.21	Appliance inlet has no accessible live parts		N/A
	- appliance inlet allows easy insertion of connector		N/A
	- after insertion of connector, tool not supported by the connector during any position of normal use on a flat surface		N/A
	Standard test finger applied for tool inlet other than appliance inlet per IEC 60320		N/A
	Appliance inlet complies with IEC 60320		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
25	TERMINALS FOR EXTERNAL CONDUCTORS		
25.1	Type X attachment, other than specially prepared cord, provided with terminal connections made by screws, nuts, or equally effective devices		N/A
	Use of screw-type terminals per IEC 60998-2-1		N/A
	Use of screwless-type terminals per IEC 60998-2-2		N/A
	Use of clamping units according to IEC 60999-1 considered equally effective devices		N/A
	Screws and nuts do not fix other components		N/A
	Screws and nuts allowed to also clamp internal conductors when they are unlikely to be displaced when fitting supply conductors		N/A
	For tool with type X attachment, soldered connections allowed to be used for connection of external conductors, when soldering alone is not used to maintain conductor in position		N/A
	When provided, barriers prevent creepages and clearances between live parts and other metal parts from being reduced to < 50% of values in 28.1, the conductor can be fixed by soldering alone		N/A
	For type Y and Z attachments, soldered, welded, crimped and similar connections allowed for the connection of external conductors		P
	Class II tools, conductor so positioned or fixed that soldering, crimping, or welding alone not relied upon to maintain the conductor in the position		N/A
	Barriers prevent creepages and clearances between live parts and other metal parts from being reduced to < 50% of values in 28.1 for the Class of tool using Type Y or Z attachments		P
	Conductors connected by soldering are held in place near termination independent of solder		N/A
	Conductor is "hooked in" before soldering and the hole through which it passes is not too large		P
	Terminals of a component built into the tool used to secure external conductors		N/A
	Leads additionally fixed near terminations		N/A
	Stranded conductors secured at insulation and conductor		P
25.2	Terminals for type X attachment fitted with special connection or accommodate nominal cross-sectional areas as in Table 8		N/A
	Cables or cords of the specified smallest and largest cross-sectional areas can be fitted (mm ²)		N/A
	Supply cord terminals withstood pull force of 5 N		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
25.3	For type X attachment, when clamping means tightened or loosened, terminal did not loosen up, no stress on internal wiring, and creepage and clearances not reduced		N/A
	Torque applied per IEC 60999-1, Clause 9.6 at 2/3 torque of that in Table 4 of IEC 60999-1 (Nm)		N/A
	Terminals secured by two screws to prevent loosening		N/A
	Correct position of supply terminals maintained by switches and similar devices with recesses and verified after connection of supply cable and repositioning of device		N/A
	Sealing compound without other means of locking not used		N/A
	Self-hardening resins used only on terminals that are not subject to torsion in normal use		N/A
25.4	Type X attachment using terminals to clamp the conductor between metal surfaces do so without damage to conductor after torque test per Cl. 25.3		N/A
25.5	Type X attachments which require no special preparation of conductor for correct connection, and conductor does not slip out when clamping screws or nuts tightened		N/A
	Type X specially prepared cord used.....	-	N/A
	There were no deep or sharp indentations on the conductors after torque test per Clause 25.3		N/A
25.6	End of conductor inserted in the hole of pillar type terminals is visible, or can pass beyond threaded hole for a distance of half nominal diameter of screw, or 2.5 mm, the greater of the two (mm)		N/A
25.7	For type X attachment, terminals clearly recognizable and accessible after opening the tool		N/A
	All terminals located behind one cover, or one part of the enclosure		N/A
25.8	Terminal devices not accessible without the aid of a tool		P
25.9	For tool with type X attachment, terminal devices located or shielded to prevent a strand of wire from escaping		N/A
	In case of class II tool, live parts and metal parts separated from accessible metal parts by supplementary insulation		N/A
	8 mm long free wire of the stranded supply conductor did not touch any accessible metal part		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

	8 mm long free wire of stranded conductor connected to an earthing terminal did not touch any live part		N/A
--	---	--	-----

26	PROVISION FOR EARTHING		
26.1	Accessible metal parts of class I tool permanently connected to an earthing terminal or termination within the tool		P
	Accessible metal parts of class I tool permanently connected to the earthing contact of the tool inlet		N/A
	Printed circuit boards are not used to provide continuity of protective earthing circuit		P
	No electrical connection between earthing terminals or contacts and neutral terminal		P
	No provisions for earthing in Class II and III tools		N/A
	Metal parts behind a decorative cover that do not withstand test of Clause 20 considered accessible metal parts		N/A
26.2	Clamping means of earthing terminals adequately locked against accidental loosening		P
	Earthing connections not possible to loosen without the aid of a tool		P
	Terminals with screw clamping comply with the relevant requirements of Clause 25, and screwless terminals comply with IEC 60998-2-2		P
	For specially prepared cords, terminals comply with IEC 60760		N/A
	Screwless terminals tested per IEC 60998-2-2		N/A
26.3	Earth connection of detachable parts was made before the current-carrying connections established when placing the part in position, and the current carrying connections separated before earth connection was broken when removing the part		N/A
	If cord slips out of cord anchorage, current-carrying conductors become taut before earthing conductor		P
26.4	No risk of corrosion between metal parts of earthing terminals and copper of earthing conductor		P
	Parts transmitting current in case of an insulation fault, other than parts of metal frame or enclosure, are coated or uncoated metal with adequate resistance to corrosion		N/A
	Thickness of electroplated coating (μm).....:		N/A
	Parts of coated or uncoated metal providing or transmitting contact pressure only, adequately protected against rusting		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Protection provided against risk of corrosion resulting from contact between copper and aluminium (or aluminium alloy)		N/A
	Parts subjected to a treatment such as chromate conversion coating are used only to provide or transmit contact pressure		N/A
	Thickness of coating of steel measured in accordance with ISO 2178 or ISO 1463 (μm).....:		N/A
	Resistance to rusting test.....:	See also Clause 30	N/A
26.5	Resistance of earthing circuit (max. 0.1 Ω).....:	0,031	P
	Test current (A).....:	25	—
	Voltage drop between the earthing terminal and accessible metal part (V).....:	12	—

27	SCREWS AND CONNECTIONS		
27.1	Fixings and electrical connections (includes earthing connections) withstood mechanical stresses occurring in normal use		P
	Screws not made of soft metal such as zinc or aluminium		P
	Diameter of screws of insulation material (mm).	-	N/A
	Screws transmitting electrical contact pressure screw into metal		P
	Screws made from insulating material are not used if their replacement by a metal screw could impair supplementary or reinforced insulation		N/A
	Screws removed when replacing the supply cord with type X attachment, or during maintenance, are not of insulating material where their replacement by a metal screw could impair basic insulation		N/A
	Screws and nuts tightened and loosened 10 times for screw engaged with a thread of insulating material	anchorage screw grip screw	P
	Nuts and other screws tightened and loosened five times	earthing screw terminal screw on switch	P
	Screws engaging with a thread of insulating material completely removed and reinserted each time		P
	When testing terminal screws and nuts, a flexible conductor of the largest cross-sectional area per Clause 25.2 placed in the terminal (mm^2).....:	1,5 mm^2	P
	Torque per column I of Table 9 applied to metal screw without head (Nm)	-	N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Torque per column II of Table 9 applied to other metal screws and nuts (Nm)	0,8 Nm, earthing screw 0,8 Nm, terminal screw 1,2 Nm, anchorage screw 1,2 Nm, grip screw	P
	Torque per column II of Table 9 applied to screws of insulating material, having a hexagonal head with dimension across flats exceeding the overall thread diameter (Nm)		N/A
	Torque (column II, Table 9) applied to screws of insulating material, with cylindrical head and a socket for a key, having cross-corner dimension exceeding overall thread diameter (Nm)		N/A
	Torque per column II of Table 9 applied to screws of insulating material, with a head having a slot or cross slots, the length of which exceeds 1.5 times the overall thread diameter (Nm)		N/A
	Torque per column III of Table 9 applied to other screws of insulating material (Nm).....		N/A
	Conductor moved each time the screw or nut was loosened		P
	No damage impairing further use of fixing or electrical connections		P
27.2	Contact pressure not transmitted through insulating material other than ceramic, unless compensated for shrinkage or distortion		N/A
27.3	Space-threaded screws not used for connection of current-carrying parts		P
	No thread-cutting screws used for connection of current-carrying parts		N/A
	Use of two space-threaded or thread-cutting screws in earthing circuits		N/A
27.4	Screws making both mechanical and electrical connections are locked against loosening		N/A
	Rivets for current-carrying connections subjected to torsion in normal use locked against loosening		N/A

28	CREEPAGE DISTANCES, CLEARANCES AND DISTANCES THROUGH INSULATION		
28.1	Creepage and clearances not less than the values in Table 10, except for cross-over points of motor windings.....	See appended Table 28.1	P
	When a resonance voltage occurs, creepage and clearance are not less than specified for the voltage imposed by the resonance; these values increased by 4 mm in case of reinforced insulation		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Creepage and clearances for a tool with an appliance inlet measured with an appropriate connector inserted		N/A
	Creepage and clearances on tools with Type X attachment measured with supply conductor of largest cross-section per Clause 25.2 (mm ²)		N/A
	Measurements repeated without the conductors		N/A
	Creepage and clearances on a tool with other attachment measured on the "as delivered" tool		P
	Measurements on tool with belt made with the belt in place and belt tension adjusted to the most unfavourable position within its adjustment range		N/A
	Measurements repeated with the belt removed		N/A
	Movable parts placed in the most unfavourable position; nuts and screws with non-circular heads tightened in the most unfavourable position		P
	Clearances between terminals and accessible metal parts also measured with screws and nuts unscrewed as far as possible and they were not less than 50% of Table 10	See Table appended 28.1	P
	Distances through slots or openings in external parts of insulating material measured to metal foil in contact with accessible surface with the foil pushed into corners using standard test finger	See appended Table 28.1	P
	2 N force applied by test finger to bare conductors and uninsulated capillary tubes of thermostats and similar devices while measurement made		P
	30 N force applied by test finger to enclosure		P
	Measurements made according to Annex A	See appended Table 28.1	P
	Creepage on an interposed barrier consisting of two parts not cemented together also measured through the joint		N/A
	Clearances on an interposed barrier measured over the barrier or, when barrier consisted of two parts with mating surfaces not cemented together, through the joint.	See appended Table 28.1	N/A
	Creepage and clearances on a tool having parts with double insulation and no metal between basic insulation and supplementary insulation		P
	PWB with peak voltage stresses ≤ 150 V per mm between parts of different potential provided with a min. distance of 0.2 mm, when protected against deposition of dirt	See appended Table 28.1	N/A
	-PWB with 100 V per mm provided with a min. distance of 0.5 mm, when not protected against deposition of dirt	See appended Table 28.1	N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Values of the table applied when limits mentioned above resulted in higher values than in the table	See appended Table 28.1	N/A
	Reduced creepage distances applied for peak voltages ≥ 50 V if Proof Tracking Index (PTI) of PWB, per Annex G, greater than 175 (PTI).....:	See appended Table 28.1	N/A
	Distances reduced further since the tool complied with the requirements of Clause 18 distances short-circuited one at a time	See appended Table 28.1	N/A
	Creepage and clearances within optocouplers not measured when individual insulation adequately sealed, with air excluded between material layers		N/A
	For live parts of different polarity separated by basic insulation only, creepage and clearances reduced as tool complied with Clause 18 when creepage and clearances short-circuited	See appended Table 28.1	N/A
28.2	Distance through insulation between metal parts was ≥ 1.0 mm for working voltages ≥ 130 V when separated by supplementary insulation	See appended Table 28.2	N/A
	Distance through insulation between metal parts was ≥ 1.5 mm for working voltages ≥ 130 V when separated by reinforced insulation	See appended Table 28.2	N/A
	Distance through the insulation was ≥ 1.0 mm for reinforced insulation used between windings and accessible metal	See appended Table 28.2	N/A
	Distance through insulation between metal parts was ≥ 1.0 mm for working voltages > 130 V ≥ 250 V when separated by supplementary insulation, and ≥ 2.0 mm when separated by reinforced insulation	See appended Table 28.2	P
	– requirement waived as insulation applied was in thin sheet form, other than mica or similar, and for supplementary insulation consisting of at least two layers, one layer having withstood electrical strength test for supplementary insulation		N/A
	– requirement waived as insulation applied was of at least three layers and for reinforced insulation, two layers in contact having withstood the electric strength test for reinforced insulation		N/A
	– requirement waived as max. temperature rise determined during test of Cl. 12 did not exceed values in 12.5 for inaccessible supplementary or reinforced insulation		N/A
	–requirement waived as inaccessible reinforced or supplementary insulation, after conditioning for 168h at temperature 50 K greater than max rise determined per Cl. 12, withstood an electric strength test per Cl. 15 at the oven temperature and room temperature ($^{\circ}$ C).....:		N/A

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict
	For optocouplers, 168 h of conditioning at 50 K higher than the max. temperature rise measured on optocouplers during tests of Clauses 12 and 18, while operating under most difficult conditions		N/A

29	RESISTANCE TO HEAT, FIRE AND TRACKING		
29.1	External parts of non-metallic material, insulating material supporting live parts, connections and thermoplastics providing supplementary or reinforced insulation sufficiently resistant to heat		P
	Relevant parts subjected to ball-pressure test subsequent to a 24 h exposure to 15 °C-35 °C, and a relative humidity between 45 % and 75 %	See Table 29.1	P
	For coil formers, parts supporting or retaining terminals in position subjected to test	See Table 29.1	N/A
29.2	Part of non-metallic material, except for decorative trims, knobs, and other parts not likely to be ignited or propagate flames originating from inside the tool, are resistant to ignition and spread of fire		P
	Parts of non-metallic material other than material classified at least HB40 per IEC 60695-11-10, provided test sample not thicker than relevant part, comply with glow-wire test of IEC 60695-2-11:	See Table 29.2	N/A
	Soft, foamy, and similar materials which cannot be subjected to glow wire test complied with ISO 9772 for category HBF material with test sample not thicker than relevant part		N/A
29.3	Insulating materials resistant to tracking		P
	Proof tracking test of Annex G conducted on insulating materials used under severe or extra-severe duty conditions:	See Table 29.3A	P
	For parts of insulating material used under severe duty conditions, test voltage was 175 V		P
	When specimens did not withstand above test and there was no hazard other than fire, surrounding parts subjected to needle-flame test of Annex F	See Table 29.3B	N/A
	For parts of insulating material used under extra-severe duty conditions, test voltage was 250 V		N/A
	When specimens did not withstand above test, but withstood test conducted at 175 V, and there was no hazard other than fire, surrounding parts subjected to needle-flame test of Annex F	See Table 29.3B	N/A
	Needle-flame test on all parts of non-metallic material positioned within a distance of 50 mm from any place where a tracking path may occur		N/A

IEC 60745-1								
Clause	Requirement + Test				Result - Remark		Verdict	
	A separate barrier or enclosure shielding parts from the tracking path, subjected to needle-flame test						N/A	
30	RESISTANCE TO RUSTING						N/A	
31	RADIATION, TOXICITY, AND SIMILAR HAZARDS						N/A	
ANNEX B	MOTORS NOT ISOLATED FROM THE SUPPLY MAINS AND HAVING BASIC INSULATION NOT DESIGNED FOR THE RATED VOLTAGE OF THE TOOL						N/A	
ANNEX F	NEEDLE-FLAME TEST						N/A	
ANNEX G	PROOF TRACKING TEST							
	Proof tracking test according to IEC 60112 and as modified in this Annex				See Table 29.3A		P	
ANNEX I	SWITCHES						N/A	
ANNEX K	BATTERY TOOLS AND BATTERY PACKS						N/A	
ANNEX L	BATTERY TOOLS AND BATTERY PACKS PROVIDED WITH MAINS CONNECTION OR NON-ISOLATED SOURCES						N/A	
ANNEX M	SAFETY OF WORKING STANDS FOR OPERATION WITH HAND-HELD MOTOR-OPERATED ELECTRIC TOOLS						N/A	
9.1	TABLE: Protection against access to live parts						N/A	
	Measurement between relevant parts and poles of supply source		Rated voltage U (V)	Measured voltage (V)	Measured current (A)	Measured capacitance (µF)		
	Supplementary information:							
11.1	TABLE: Input data under no load conditions						P	
	Rated voltage U(V)			Rated input (W) or current I (A)	Measured input (W) or current (A)	Deviation	Load condition / Remarks	
	Single Voltage (V)	Lower Voltage Limit (V)	Upper Voltage Limit (V)					Mean Value of Range
	-	220	240	230	2800 W	1259 W	222 %	No load
	-	110	120	115	1700 W	1066 W	159 %	No load

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

Supplementary information: Optional: Locked Rotor Current _____ Amps

12.1A	TABLE: Temperature rise measurements under the conditions of 12.2, 12.4, & 12.5 (220-240 V version)		P
Test voltage	207 / 220 / 240 / 254 V		—
Ambient temperature (°C)	23,4/ 23,7/ 23,3/ 24,1 °C		—
Operating time	30 min		—
Normal Load Speed	2512/ 2713/ 2992/ 3172 /min		—
Input current (A) / Input Wattage (W)	11,57/ 11,68/ 11,88/ 11,96 A 2469/ 2679/ 2967/ 3171 W		—
Torque (Nm)	6,10		—
Measurement at:	Temperature rise in K	Allowed Limit	
Ambient of switch	19	30	
Power cord	10	50	
Internal wire near motor	15	50	
Support of PCB	12	Ref.	
Handle	12	50	
Switch knob	12	60	
Enclosure	34	60	
Aux. handle	12	Ref.	
Stator core	44	Ref.	
PCB	9	120	
X2 capacitor	8	50	
Supplementary Information: Note: See Table 13.1A for Leakage Current Test after Temperature Test			

12.3A	TABLE: Temperature Rise of Windings (220-240 V version)					P
Part under test (windings and core laminations)	R ₁ (Ω)	R ₂ (Ω)	dT (K) by resistance	dT (K) by thermocouples	Allowed dT (K)	Insulation Class
Stator (1)	0,338	0,469	100	-	140	Class 180
Stator (2)	0,339	0,470	100	-	140	Class 180
Rotor (diagonal)	0,420	0,631	130	-	140	Class 180
Supplementary Information: Note: See Table 13.1A for Leakage Current Test after Temperature Test t ₁ =22,5 °C						

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

12.1B	TABLE: Temperature rise measurements under the conditions of 12.2, 12.4, & 12.5 (110-120 V version)		P
Test voltage	103/110/120/127		—
Ambient temperature (°C)	24,0/ 24,1/ 24,2/ 23,9 °C		—
Operating time	30 min		—
Normal Load Speed	2587/ 2809/ 3016/ 3229 /min		—
Input current (A) / Input Wattage (W).....	14,68/ 14,91/ 15,12/ 15,51 A 1497/ 1650/ 1820/ 2012 W		—
Torque (Nm)	3,12		—
Measurement at:	Temperature rise in K	Allowed Limit	
Ambient of switch	24	30	
Power cord	13	50	
Internal wire near motor	11	50	
Support of PCB	9	Ref.	
Handle	8	50	
Switch knob	5	60	
Enclosure	25	60	
Aux. handle	9	Ref.	
Stator core	30	Ref.	
PCB	8	120	
X2 capacitor	6	50	
Supplementary Information: Note: See Table 13.1A for Leakage Current Test after Temperature Test			

12.3B	TABLE: Temperature Rise of Windings (110-120 V version)					P
Part under test (windings and core laminations)	R ₁ (Ω)	R ₂ (Ω)	dT (K) by resistance	dT (K) by thermocouples	Allowed dT (K)	Insulation Class
Stator (1)	0,0988	0,1148	41,4	-	140	Class 180
Stator (2)	0,0986	0,1151	42,8	-	140	Class 180
Rotor (diagonal)	0,1461	0,1920	80,7	-	140	Class 180
Supplementary Information: Note: See Table 13.1A for Leakage Current Test after Temperature Test t ₁ =23,5 °C						

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

13.1A	TABLE: Leakage Current – Clause 12.1					P
Points of application	Test voltage (1.06 X rated V)	Freq. (Hz)	Selector Switch Position (ON/ OFF ¹)	Allowed leakage current (mA)	Measured leakage (mA)	
L/N and body (main switch on)	127 V	50 Hz	ON	0,75	0,01 / 0,01	
L/N and body (main switch on)	254 V	50 Hz	ON	0,75	0,01 / 0,01	
Supplementary Information: Note ⁽¹⁾ – Testing with tool in the “OFF” position is required when tool employs a single pole switch and a capacitor						

13.1B	TABLE: Leakage Current – Clause 12.6 d)					N/A
Points of application	Test voltage (1.06 X rated V)	Freq. (Hz)	Selector Switch Position (ON / OFF ¹)	Allowed leakage current (mA)	Measured leakage (mA)	
Supplementary Information: Note ⁽¹⁾ – Testing with tool in the “OFF” position is required when tool employs a single pole switch and a capacitor						

13.1C	TABLE: Leakage Current – Clause 14.3					P
Points of application	Test voltage (1.0 X rated V)	Freq. (Hz)	Selector Switch Position (ON / OFF ¹)	Allowed leakage current (mA)	Measured leakage (mA)	
L/N and body (main switch on)	120 V	50 Hz	OFF	0,75	0,01 / 0,01	
L/N and body (main switch on)	240 V	50 Hz	OFF	0,75	0,01 / 0,01	
Supplementary Information: Note ⁽¹⁾ – Testing with tool in the “OFF” position is required when tool employs a single pole switch and a capacitor						

13.1D	TABLE: Leakage Current – Clauses 14.4, 14.5 and 18.12						P
Points of application	Test voltage (V)	Freq. (Hz)	Selector Switch Position (ON/OFF ¹)	Allowed leakage current ² (mA)	Measured leakage current (mA)	Mode ³ , test condition ⁴ and/or additional Comments	
L / N and enclosure	120 V	50 Hz	ON	0,75	0,01 / 0,01	Clause 14,4 a)	
L / N and enclosure	120 V	50 Hz	ON	5	0,01 / 0,01	Clause 14,4 b)	
L / N and enclosure	120 V	50 Hz	ON	0,75	0,01 / 0,01	Clause 14,5 a)	
L / N and enclosure	120 V	50 Hz	ON	5	0,01 / 0,01	Clause 14,5 b)	
L / N and enclosure	120 V	50 Hz	ON	2	0,13 / 0,13	Clause 18.12	
L / N and enclosure	240 V	50 Hz	ON	0,75	0,01 / 0,01	Clause 14,4 a)	
L / N and enclosure	240 V	50 Hz	ON	5	0,01 / 0,01	Clause 14,4 b)	
L / N and enclosure	240 V	50 Hz	ON	0,75	0,01 / 0,01	Clause 14,5 a)	
L / N and enclosure	240 V	50 Hz	ON	5	0,01 / 0,01	Clause 14,5 b)	

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

L / N and enclosure	240 V	50 Hz	ON	2	0,13 / 0,13	Clause 18.12
---------------------	-------	-------	----	---	-------------	--------------

Supplementary Information:

Note ⁽¹⁾ – Testing with tool in the “OFF” position is required when tool employs a single pole switch and a capacitor

Note ⁽²⁾ – 2 mA for a class II tool, 5 mA for a class I tool

Note ⁽³⁾ – Applicable mode, see Clause 14.4

Note ⁽⁴⁾ – Test condition such as 1.0 % NaCl solution at specified pressure for 1 h (Clause 14.5), disable residual current device (Cause 14.5), measurement after tool allowed to dry for 24 h at room temperature, etc.

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

15.2A	TABLE: Electric Strength Test – Applied after Clause 12.6 d)			N/A
Test voltage applied between:	Class of tool	Test voltage (V)	Results after Clause 12.6 d)	Remarks
Between live parts and accessible parts separated from live parts by basic insulation only	Class III	500		
	Other tools	1250		
Between live parts and accessible parts separated from live parts by reinforced insulation	Class II and II Builds	3750		
	Other tools	3750		
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and live parts	Class II and II Builds	1250		
	Other tools	1250		
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and accessible parts	Class II and II Builds	2500		
	Other tools	2500		
Between metal enclosures or covers lined with insulating material and metal foil in contact with the inner surface of the lining	Class II and II Builds	2500		
	Other tools	1250		
Between metal foil in contact with handles and the like and their shafts	Class II and II Builds	2500		
	Other tools	2500		
Between accessible parts and internal diameter of cord guard wrapped with metal foil	Class II and II Builds	2500		
	Other tools	1250		
Between winding/capacitor connection and accessible parts	Class II and II Builds	2U + 1000		
Between winding/capacitor connection and metal parts separated from live parts by basic insulation only	Other tools	2U + 1000		
Supplementary Information:				

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

15.2B	TABLE: Electric Strength Test – Applied after Clause 14.1.2, 14.2, & 14.3				P
Test voltage applied between:	Class of tool	Test voltage (V)	Results after Clause 14.1.2	Results after Clause 14.2	Results after Clause 14.3
Between live parts and accessible parts separated from live parts by basic insulation only	Class III	500	N/A	N/A	N/A
	Other tools	1250	N/A	N/A	P
Between live parts and accessible parts separated from live parts by reinforced insulation	Class II and II Builds	3750	N/A	N/A	N/A
	Other tools	3750	N/A	N/A	P
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and live parts	Class II and II Builds	1250	N/A	N/A	N/A
	Other tools	1250	N/A	N/A	N/A
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and accessible parts	Class II and II Builds	2500	N/A	N/A	N/A
	Other tools	2500	N/A	N/A	P
Between metal enclosures or covers lined with insulating material and metal foil in contact with the inner surface of the lining	Class II and II Builds	2500	N/A	N/A	N/A
	Other tools	1250	N/A	N/A	N/A
Between metal foil in contact with handles and the like and their shafts	Class II and II Builds	2500	N/A	N/A	N/A
	Other tools	2500	N/A	N/A	N/A
Between accessible parts and internal diameter of cord guard wrapped with metal foil	Class II and II Builds	2500	N/A	N/A	N/A
	Other tools	1250	N/A	N/A	N/A
Between winding/capacitor connection and accessible parts	Class II and II Builds	2U + 1000	N/A	N/A	N/A
Between winding/capacitor connection and metal parts separated from live parts by basic insulation only	Other tools	2U + 1000	N/A	N/A	N/A
Supplementary Information:					

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

15.2C	TABLE: Electric Strength Test – Applied after Clause 17.2			P
Test voltage applied between:	Class of tool	Test voltage (V)	Results	
Between live parts and accessible parts separated from live parts by basic insulation only	Class III	375	N/A	
	Other tools	937.5	N/A	
Between live parts and accessible parts separated from live parts by reinforced insulation	Class II and II Builds	2812.5	P	
	Other tools	2812.5	N/A	
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and live parts	Class II and II Builds	937.5	P	
	Other tools	937.5	N/A	
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and accessible parts	Class II and II Builds	1875	P	
	Other tools	1875	N/A	
Between metal enclosures or covers lined with insulating material and metal foil in contact with the inner surface of the lining	Class II and II Builds	1875	N/A	
	Other tools	937.5	N/A	
Between metal foil in contact with handles and the like and their shafts	Class II and II Builds	1875	N/A	
	Other tools	1875	N/A	
Between accessible parts and internal diameter of cord guard wrapped with metal foil	Class II and II Builds	1875	N/A	
	Other tools	937.5	N/A	
Between winding/capacitor connection and accessible parts	Class II and II Builds	$(2U+1000) * 0.75$	N/A	
Between winding/capacitor connection and metal parts separated from live parts by basic insulation only	Other tools	$(2U+1000) * 0.75$	N/A	
Supplementary Information:				

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

15.2D	TABLE: Electric Strength Test – Applied after Clause 17.3			N/A
Test voltage applied between:	Class of tool	Test voltage (V)	Results	
Between live parts and accessible parts separated from live parts by basic insulation only	Class III	500		
	Other tools	1250		
Between live parts and accessible parts separated from live parts by reinforced insulation	Class II and II Builds	3750		
	Other tools	3750		
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and live parts	Class II and II Builds	1250		
	Other tools	1250		
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and accessible parts	Class II and II Builds	2500		
	Other tools	2500		
Between metal enclosures or covers lined with insulating material and metal foil in contact with the inner surface of the lining	Class II and II Builds	2500		
	Other tools	1250		
Between metal foil in contact with handles and the like and their shafts	Class II and II Builds	2500		
	Other tools	2500		
Between accessible parts and internal diameter of cord guard wrapped with metal foil	Class II and II Builds	2500		
	Other tools	1250		
Between winding/capacitor connection and accessible parts	Class II and II Builds	2U + 1000		
Between winding/capacitor connection and metal parts separated from live parts by basic insulation only	Other tools	2U + 1000		
Supplementary Information:				

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

15.2E	TABLE: Electric Strength Test – Applied after Clause 20.2, 20.3 and 20.4					P
Test voltage applied between:	Class of tool	Test voltage (V)	Results after 20.2	Results after 20.3	Results after 20.4	
Between live parts and accessible parts separated from live parts by basic insulation only	Class III	500	N/A	N/A	N/A	
	Other tools	1250	N/A	N/A	N/A	
Between live parts and accessible parts separated from live parts by reinforced insulation	Class II and II Builds	3750	P	P	N/A	
	Other tools	3750	N/A	N/A	N/A	
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and live parts	Class II and II Builds	1250	P	P	N/A	
	Other tools	1250	N/A	N/A	N/A	
For parts with double insulation, between metal parts separated from live parts by basic insulation only, and accessible parts	Class II and II Builds	2500	P	P	N/A	
	Other tools	2500	N/A	N/A	N/A	
Between metal enclosures or covers lined with insulating material and metal foil in contact with the inner surface of the lining	Class II and II Builds	2500	N/A	N/A	N/A	
	Other tools	1250	N/A	N/A	N/A	
Between metal foil in contact with handles and the like and their shafts	Class II and II Builds	2500	N/A	N/A	N/A	
	Other tools	2500	N/A	N/A	N/A	
Between accessible parts and internal diameter of cord guard wrapped with metal foil	Class II and II Builds	2500	N/A	N/A	N/A	
	Other tools	1250	N/A	N/A	N/A	
Between winding/capacitor connection and accessible parts	Class II and II Builds	2U + 1000	N/A	N/A	N/A	
Between winding/capacitor connection and metal parts separated from live parts by basic insulation only	Other tools	2U + 1000	N/A	N/A	N/A	
Supplementary Information:						

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

16.1	TABLE: Overload Protection of Transformers and Associated Circuits	N/A	
Supplementary Information:			

18.10.2	TABLE: Fault Condition Tests				P
	Ambient temperature (°C).....:		21,5		—
Component	Fault Condition	Test Voltage (V)	Test Duration	Fuse-link Current (A)	Comment/Result
Control module	Open-circuit	240	30s	-	No operation
Control module	Short-circuit	240	30s	-	No operation
Supplementary Information:					

23.1	TABLE: List of Critical Components					P
Object/Part No.	Manufacturer/ Trademark	Type/Model	Technical Data	Standard	Mark(s) of Conformity ¹⁾	
Supply cord*	Nexans	H07RN-F	3 G 1,5 mm ²	IEC 60245	LCIE	
Alternative	Patelec	H07RN-F	3 G 1,5 mm ²	IEC 60245	VDE	
Power plug*	Ta An Electrical	TP-52	16 A; 250 Vac	IEC 60884	VDE	
Alternative	Ta An Electrical	TP-50	16 A; 250 Vac	IEC 60884	VDE	
Alternative	Ta An Electrical	TP-51	16 A; 250 Vac	IEC 60884	VDE	
Alternative	Ching Cheng Wire Material	EL-208	16 A; 250 Vac	SANS 164-1 SABS 164-1	SABS	
Alternative	Ta An Electrical	TP-22	15 A; 250 VAC	IEC 60884	SAA	
Alternative	Patelec	PC-538	20 A; 250 Vac	NBR 60884	TUV/ INMETRO	
Alternative	Patelec	PC-507	16 A; 250 Vac	SANS 164-1 SABS 164-1	SABS	
BS plug only for 220-240 V	Ta An Electrical	TP-66	250 Vac; 13 A fuse included	BS 1363	ASTA	
Power plug for 110-120 V*	Ningbo Znpou	P1134	110-130 V; 16 A; IP44	IEC 60309	SEMKO	
Switch	Defond	BGV-2115	250 Vac; lock-off 15(15) A; 5E4	IEC 61058-1	ENEC15	
X2 capacitor**	Carli Electronics	MPX	0,47µF; 275 Vac	IEC 60384-14	VDE	
Alternative	Aid Electronics	MEX	0,47µF; 275 Vac	IEC 60384-14	VDE	
PWB	Taiwan Lord	PCB-C14	250 Vac	IEC 60745	Tested in Appliance	

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

Object/Part No.	Manufacturer/ Trademark	Type/Model	Technical Data	Standard	Mark(s) of Conformity ¹⁾
PRCD	Wehzhou Bestfun	RCD05	220-240 Vac; 16 A; 10 mA; IP55	IEC 61540	TUV

1) An asterisk indicates a mark which assures the agreed level of surveillance

*) or other certified plugs or cables with the same technical data

***) or any other certified brand/type with equivalent ratings and the same construction.

28.1	TABLE: Clearance and Creepage Distance Measurements						P
Clearance cl and Creepage Distance (dcr) Between:	Up (V)	U r.m.s. (V)	Required cl (mm)	cl (mm)	Required dcr (mm)	Dcr (mm)	
L and N on switch	-	240	2,5	>5	3	>5	
Stator winding and core	-	240	2,0	3,1	2,0	3,1	
Rotor winding and core	-	240	2,0	2,3	2,0	2,3	
Internal wire and enclosure	-	240	4,0	5,1	4,0	5,1	
Commutator and bearing	-	240	8,0	10,2	8,0	10,2	
Rotor winding and bearing	-	240	6,0	>9	6,0	>9	

Supplementary information:
- Creepage and clearance values of Table 10 do not apply to crossover points of motor windings.

28.2	TABLE: Distance Through Insulation Measurements				P
Distance Through Insulation di Between:	U r.m.s. (V)	Test Voltage (V)	Required di (mm)	Di (mm)	
Metal parts separated by supplementary insulation	240	N/A	1,0	>1	
Accessible metal parts separated by reinforced insulation	240	N/A	2,0	>2	

Supplementary information:

29.1	TABLE: Ball Pressure Test			P
Part under test	Plastic material type	Test Temperature (°C)	Impression Diameter (mm)	
Enclosure	-	125	1,0	
Plastic support of PCB	-	125	1,2	
Handle	-	75	1,2	

Supplementary information:

29.2	TABLE: Glow Wire Test		P
Test Conditions.....:	Test according to IEC 60695-2-11		—
Test temperature (°C)	550°C		—

IEC 60745-1			
Clause	Requirement + Test	Result - Remark	Verdict

Test Specimen	Material type	Specified Layer placed underneath Test Specimen	Material ignited, Yes/No	Specified Layer under Test Specimen ignited, Yes/No	Other remarks
Enclosure	-	No	No	No	Pass
Plastic support of PCB	-	No	No	No	Pass
Handle	-	No	No	No	Pass
Supplementary information:					

29.3A	TABLE: Proof Tracking Test, Annex G				P
Test Conditions..... :	Test according to IEC 60112				—
Test solution	0,1 % NH ₄ CL				—
Test Voltage (V)..... :	175 V				—
Specimen under test	Material type	Tracking occurred, Yes/No	Rate of Tracking	Other remarks	
Enclosure	-	No	2 drops /min	Pass	
Plastic support of PCB	-	No	2 drops /min	Pass	
Handle	-	No	2 drops /min	Pass	
Supplementary information:					

29.3B	TABLE: Needle-flame Test, Annex F	N/A
-------	-----------------------------------	-----

K12.1	TABLE: Normal Temperature Test for Battery Tool	N/A
-------	---	-----

K.18.1	TABLE: Battery Tool Abnormal Operation	N/A
--------	--	-----

L.18.201	TABLE: Battery Tool Abnormal Operation	N/A
----------	--	-----



Photos:




























220-240 V



220-240 V



110-120 V



110-120 V



End